

PAT Report Results Multiple Tests For all Sites and Locations

CLIENT DETAILS	
Company Name:	ANNS EVENTS HIRE
Address:	THE LODGE & ANNEX BUILDING HARMONDSWORTH LANE WEST DRAYTON UB7 0LQ



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING	
Company Name:	IGT ELECTRICAL
Address:	81 Patten Ash Drive Wokingham Berkshire RG40 1SH
Telephone:	
Mobile:	07735981627
Email:	info@igtelectrical.com
Cert Number:	18-000371
Order Number:	
Signature:	

APPLIANCE DETAILS AND TEST RESULTS

Key P = PASS / F = FAIL / S = SKIP (or test not applicable)										
Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status	
- STORAGE										
1901	IEC LEAD	14/09/23	P	P	P 0.07	P >19.9	S	S	PASS	
1902	IEC LEAD	14/09/23	P	P	P 0.08	P >19.9	S	S	PASS	
1903	POWERCON CABLE	14/09/23	P	P	P 0.05	P >19.9	S	S	PASS	
1904	POWERCON CABLE	14/09/23	P	P	P 0.04	P >19.9	S	S	PASS	
1905	POWERCON CABLE	14/09/23	P	P	P 0.05	P >19.9	S	S	PASS	
1906	POWERCON CABLE	14/09/23	P	P	P 0.04	P >19.9	S	S	PASS	
1907	POWERCON CABLE	14/09/23	P	P	P 0.03	P >19.9	S	S	PASS	
1908	POWERCON CABLE	14/09/23	P	P	P 0.03	P >19.9	S	S	PASS	
1909	POWERCON CABLE	14/09/23	P	P	P 0.09	P >19.9	S	S	PASS	
1910	POWERCON CABLE	14/09/23	P	P	P 0.08	P >19.9	S	S	PASS	
1911	UP LIGHT	14/09/23	P	S	S	P >19.9	S	P 0.25	PASS	
1912	UP LIGHT	14/09/23	P	S	S	P >19.9	S	P 0.25	PASS	
1913	UP LIGHT	14/09/23	P	S	S	P >19.9	S	P 0.25	PASS	
1914	UP LIGHT	14/09/23	P	S	S	P >19.9	S	P 0.25	PASS	
1915	UP LIGHT	14/09/23	P	S	S	P >19.9	S	P 0.25	PASS	
1916	UP LIGHT	14/09/23	P	S	S	P >19.9	S	P 0.25	PASS	
1917	UP LIGHT	14/09/23	P	S	S	P >19.9	S	P 0.25	PASS	
1918	UP LIGHT	14/09/23	P	S	S	P >19.9	S	P 0.25	PASS	
1919	LIGHT BAR	14/09/23	P	S	P 0.04	P >19.9	S	P 0.75	PASS	

Total Appliances > 19

Total Appliances For Report: 19